



NOTE 1: TT(S) AND TG(S) ARE 11/2" FLANGE TYPE AND ACCORDING TO ANSI B16.5 ,EXCEPT FOR RATING 1500# AND HIGHER THAT ARE WELDED TYPE(IF ANY) .
 NOTE 2: ALL SIGNALS WILL BE REPEATED IN FCS (BY REDUNDANT MODBUS) .
 NOTE 3: BEFORE 12D,AFTER 4D
 NOTE 4: ALL INSTRUMENT TAG. NUMBERS HAVE PREFIX NO OF 11 . FOR EXAMPLE 11-LT-10101
 NOTE 5: HOT BYPASS CLOSED AT VALVE FAILURE POSITION
 NOTE 6: ALL THE MANUAL & CHECK VALVE IS STANDARD TYPE OF VALVE.

- No Comment
- Comment As Marked, Manufacturing May Proceed
- Major Comment As Marked, Manufacturing Shall Be On Hold For The Next Revision.
- Rejected, New Document With The Same Revision No. shall be Issued
- For Information

Name: _____ Reg. No.: _____ Ser. No.: _____
 Signature: _____ Date: _____
 Purchaser review & comments does not absolve the vendor of the responsibility for the correct design, manufacturing and operation of the equipment.

DE	Eng. Phase	Purpose of Distribution (POD)	Purpose of Issue (POI)	Purchaser's Action
12	07.05.2023	ISSUED FOR APPROVAL	Surfongmei	WuQing
11	19.01.2023	ISSUED FOR APPROVAL	Surfongmei	WangZhen
10	21.02.2022	ISSUED FOR APPROVAL	Surfongmei	WangZhen
09	07.02.2022	ISSUED FOR APPROVAL	Surfongmei	WangZhen
08	24.01.2022	ISSUED FOR APPROVAL	Surfongmei	WangZhen

REV.	ISSUE DATE	DESCRIPTION	PREPARED BY	CHECKED BY	APPROVED BY	AUTHORIZED BY
OWNER:						
MC:						
EPCC CONTRACTOR:						

PROJECT: HENGANG FERTILIZER PROJECT

VENDOR: **NEWJCM** 锦州新锦化机械制造有限公司
 Jinzhou NEWJCM Machinery manufacture Co.,Ltd

TITLE: **LUBE OIL SYSTEM (TANK) PID CO2 COMPRESSOR (11-C-101)**

SCALE: N:1.5 OWNER PROJECT NO.: NA VENDOR DWS. NO.: REV. SIZE: 12 A1
 SHT.: 1 OF 1 PDEC PROJECT NO.: 1208 PDEC DWG. NO.: VD-1208-301B-PID-403

REMARK
 A.S AIR SUPPLY
 C.S.O CAR SEAL OPEN
 F.O PORTS FAILING CLOSED
 F.O PORTS FAILING OPEN
 F.L PORTS FAILING LOCKED IN POSITION
 OPERATING CONDITIONS MEAN AS FOLLOWS.

Q:FLOW	NOR/DES	(m ³ /h)
P:PRESSURE	NOR/DES	(barG)
T:TEMPERATURE	NOR/DES	(°C)