



- NOTE: 1 ALL SIGNALS WILL BE REPEATED IN FCS(BY REDANDUNT MODBUS) .
 2 TT(S) AND TG(S) ARE 11/2" FLANGE TYPE AND ACCORDING TO ANSI B16.5 ,EXCEPT FOR RATING 1500# AND HIGHER THAT ARE WELDED TYPE(F ANY)
 3 BEFORE 12D,AFTER 4D
 4 ALL INSTRUMENT TAG NUMBERS HAS PREFIX NO. OF 11 FOR EXAMPLE 11-PT-10124
 5 ALL THE MANUAL & CHECK VALVE IS STANDARD TYPE OF VALVE.
 6 EXTRACTION CHECK VALVE SHALL BE INSTALLED AS CLOSE AS POSSIBLE TO THE EXTRACTION NOZZLE OR TURBINE.

- No Comment
- Comment As Marked, Manufacturing May Proceed
- Major Comment As Marked, Manufacturing Shall Be On Hold For The Next Revision.
- Rejected, New Document With The Same Revision No. shall Be Issued
- For Information

Name: _____ Req. No.: _____ Seq. No.: _____
 Signature: _____
 Date: _____
 Purchaser review & comments does not absolve the vendor of the responsibility for the correct design, manufacturing and operation of the equipment.

Eng. Date	Purpose of Distribution (POD)	Purpose of Issue (POI)	Purchaser's Action
08/07/2023	ISSUED FOR APPROVAL	SunHongmei, WuYang, XieShuangjun, WangZhenjun	
07/25/2022	ISSUED FOR APPROVAL	SunHongmei, WuYang, XieShuangjun, WangZhenjun	
06/10/2021	ISSUED FOR APPROVAL	SunHongmei, WuYang, XieShuangjun, WangZhenjun	
05/09/2020	ISSUED FOR APPROVAL	SunHongmei, WuYang, XieShuangjun, WangZhenjun	
05/09/2020	ISSUED FOR APPROVAL	SunHongmei, WuYang, XieShuangjun, WangZhenjun	

REV.	ISSUE DATE	DESCRIPTION	PREPARED BY	CHECKED BY	APPROVED BY	AUTHORIZED BY

OWNER:

MO:

EPC CONTRACTOR:

PROJECT: HENGAM FERTILIZER PROJECT

VENDOR: **NEWJCM** 锦州新锦化机械制造有限公司
Jinzhou NEWJCM Machinery manufacture Co.,Ltd

TITLE: PIPING AND INSTRUMENT DIAGRAM
STEAM TURBINE(11-CT-101)

SCALE: N.T.S	OWNER PROJECT NO.: NA	VENDOR DWG. NO.:	REV. SIZE:
SHT.: 1 OF 1	PIDEC PROJECT NO.: 1208	PIDEC DWG. NO.: VD-1208-301B-PID-402	08 A1